

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of \_\_\_\_\_

Name of Facility/DBA: <b>Holiday Inn Express Pool</b>				Inspection Date: <b>5/16/23</b>			
Address: <b>545 N. Humbolt Ave, willows</b>				Reinspection Date (on or after):  (Reinspections are subject to fees)			
Owner/Permittee: <b>Kumar hotels Inc</b>			Phone Number:		Inspection Time: <b>9:20 AM</b>		Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input checked="" type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other				Service: <input type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other			
pH: <b>7.4</b>	Free Chlorine: <b>4.0/5</b>	Combined Chlorine: <b>3.88/4.86</b>	Cyanuric Acid: <b>/</b>	Flow Rate: <b>50/40</b>	Temperature: <b>85</b>	Other:	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20							

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:

NO VIOLATIONS AT TIME OF INSPECTION

Received By: <b>Rory Spooner</b>	REHS: <b>Jay Bickett</b>
----------------------------------	--------------------------