

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988  
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <b>Villa Court Townhouse</b>		Inspection Date: <b>5/17/23</b>	
Address: <b>127 Villa Ct Willows CA</b>		Reinspection Date (on or after): <b>next inspection</b> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <b>Villa Court Townhomes</b>	Phone Number:	Inspection Time: <b>9:30 AM</b>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <b>7.2</b>	Free Chlorine: <b>3.42</b>	Combined Chlorine: <b>3.42</b>	Cyanuric Acid: <b>43</b>
Flow Rate:	Temperature: <b>—</b>	Other: <b>—</b>	
<i>Applicable Laws &amp; Regulations: California Health &amp; Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 &amp; Title 22, Chapter 20</i>			

<p><b>Pool Construction</b></p> <ol style="list-style-type: none"> <li>1. <input type="checkbox"/> Pool Shell</li> <li>2. <input type="checkbox"/> Bottom &amp; Sides</li> <li>3. <input type="checkbox"/> Decks &amp; Coping</li> <li>4. <input type="checkbox"/> Diving Boards</li> <li>5. <input type="checkbox"/> Depth Markers</li> <li>6. <input type="checkbox"/> Ladders/Steps/Railings</li> <li>7. <input type="checkbox"/> Underwater Lighting &amp; Electrical</li> </ol> <p><b>Recirculation Equipment</b></p> <ol style="list-style-type: none"> <li>8. <input type="checkbox"/> Filters</li> <li>9. <input type="checkbox"/> Pumps</li> <li>10. <input type="checkbox"/> Flowmeter</li> <li>11. <input type="checkbox"/> Pressure/Vacuum Gauges</li> <li>12. <input type="checkbox"/> Skimmers &amp; Gutters</li> <li>13. <input type="checkbox"/> Pipes &amp; Fittings</li> <li>14. <input type="checkbox"/> Chemical Feeders</li> <li>15. <input type="checkbox"/> Water Supply/Backflow Prevention</li> </ol>	<p><b>Water Quality</b></p> <ol style="list-style-type: none"> <li>16. <input type="checkbox"/> pH</li> <li>17. <input type="checkbox"/> Chlorine/Bromine</li> <li>18. <input type="checkbox"/> Cyanuric Acid</li> <li>19. <input type="checkbox"/> Debris in Pool</li> <li>20. <input type="checkbox"/> Water Clarity</li> <li>21. <input type="checkbox"/> Temperature</li> <li>22. <input type="checkbox"/> Flow Rate/Turnover</li> </ol> <p><b>Safety Equipment</b></p> <ol style="list-style-type: none"> <li>23. <input type="checkbox"/> Gates/Enclosure</li> <li>24. <input type="checkbox"/> Drain Covers</li> <li>25. <input type="checkbox"/> Anti-Entrapment Shutoff</li> <li>26. <input type="checkbox"/> Rescue Pole</li> <li>27. <input type="checkbox"/> Life Ring</li> <li>28. <input checked="" type="checkbox"/> Safety Signs</li> <li>29. <input type="checkbox"/> First Aid Kit</li> <li>30. <input type="checkbox"/> Chlorine Gas Safety</li> </ol>	<p><b>General Facilities</b></p> <ol style="list-style-type: none"> <li>31. <input type="checkbox"/> Exterior Lighting</li> <li>32. <input type="checkbox"/> Indoor Ventilation</li> <li>33. <input type="checkbox"/> Restrooms &amp; Toilets</li> <li>34. <input type="checkbox"/> Handwash Sinks</li> <li>35. <input type="checkbox"/> Dressing Rooms</li> <li>36. <input type="checkbox"/> Showers</li> <li>37. <input type="checkbox"/> Drinking Fountains</li> </ol> <p><b>Miscellaneous</b></p> <ol style="list-style-type: none"> <li>38. <input type="checkbox"/> Chemical Test Kits</li> <li>39. <input type="checkbox"/> Chemical Testing Frequency</li> <li>40. <input type="checkbox"/> Record Keeping</li> <li>41. <input type="checkbox"/> Lifeguards</li> <li>42. <input type="checkbox"/> Communicable Disease Control</li> <li>43. <input type="checkbox"/> Site Supervision &amp; Control</li> <li>44. <input type="checkbox"/> General Sanitation</li> <li>45. <input type="checkbox"/> Other:</li> </ol>
--	---	--

Comments:  
**28) Safety signs - Diarrhea sign lacks at the gate. / Install sign at gate.**

Received By: **x Ray Spooner**      REHS: **Jay Bhakta**