

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
 Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: PAGEWOOD APARTMENTS POOL				Inspection Date: 5/23/23	
Address: 745 PAGEDWOOD DRIVE, ORLAND, CA				Reinspection Date (on or after):	
Owner/Permittee: ORLAND PACIFIC ASSOCIATES		Phone Number: 865-1313		Inspection Time: 11:00	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other			
pH: 8.3	Free Chlorine: 7.7 PPM	Combined Chlorine: -	Cyanuric Acid: 39 PPM	Flow Rate: UNABLE TO TEST	Temperature: -
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20					

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input checked="" type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Water Quality 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Other Chemicals 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover Safety Equipment 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input checked="" type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input checked="" type="checkbox"/> General Sanitation 45. <input checked="" type="checkbox"/> Other:
--	---	---

Comments: CORRECT THE FOLLOWING:

(6) REPAIR THE CRACKED STEP AT THE DEEP END OF THE POOL

(23) LUBRICATE AND TIGHTEN THE POOL GATE SO IT SELF CLOSES & SELF LATCHES

(28) REPLACE NO DIVING SIGNS ON THE DECK

(45) ALL CHANGES TO THE POOL MUST BE PLAN CHECKED AND APPROVED BEFORE INSTALLATION BY GLENN CO. (NEW CHLORINATOR)

(45) PLEASE PROVIDE REPLACEMENT V.G.B DRAIN COVER INFO TO GLENN CO. ENVIRONMENTAL HEALTH.

Received By:  REHS: 