

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
 Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <u>Dolphin Club Pool</u>				Inspection Date: <u>5/5/23</u>			
Address: <u>233 W. 1st St., Willows</u>				Reinspection Date (on or after): <u>5/11/23</u> <small>(Reinspections are subject to fees)</small>			
Owner/Permittee: <u>contact</u> <u>Jasmine Thomas</u>			Phone Number: <u>530 330-9284</u>		Inspection Time: <u>9:00 AM</u>		Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other			Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other				
pH: <u>6.8</u>	Free Chlorine: <u>2.87</u>	Combined Chlorine: <u>3.31</u>	Cyanuric Acid: <u>10</u>	Flow Rate: <u>100</u>	Temperature: <u>—</u>	Other: <u>—</u>	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20							

<p>Pool Construction</p> <ol style="list-style-type: none"> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input checked="" type="checkbox"/> Ladders/Steps/Railings 7. <input checked="" type="checkbox"/> Underwater Lighting & Electrical <p>Recirculation Equipment</p> <ol style="list-style-type: none"> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention 	<p>Water Quality</p> <ol style="list-style-type: none"> 16. <input checked="" type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Other Chemicals 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover <p>Safety Equipment</p> <ol style="list-style-type: none"> 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety 	<p>General Facilities</p> <ol style="list-style-type: none"> 31. <input checked="" type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains <p>Miscellaneous</p> <ol style="list-style-type: none"> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:
---	--	---

Comments:

Critical Violations

16) Maintain Pool pH between 7.2-7.8. / Pool measured 6.8


17) Maintain Free available chlorine above 3.0 but less than 10.0. Pool measured @ 2.87 ppm

~~18) Both~~

10) Flowmeters shall be operational at all times. / Left flowmeter inoperational.

28) All signs shall be displayed and presented in visible to public areas. Mark signs to designate # of people and address of pool in case of emergency. Have Diarrhea sign outside of main doors.

31) exterior light shall be operational. / Restroom & exterior light inoperational / Repair

Received By:  REHS: Jay Bluketa

OFFICIAL INSPECTION REPORT

Continuation Sheet

GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

225 N. Tehama Street, Willows, CA 95988

Phone (530) 934-6102 FAX (530) 934-6103


Page 2 of 2

Name of Facility / DBA: <u>Dolphin Club</u>	Inspection Date:
Address: <u>Page 2</u>	
Owner/Permitee: <u>Page 2</u>	

Comments:

6) Ladder observed to be to be loose in ground. / cement/grout ladders to ground.

7) light in pool inoperable. / Repair if night swimming Hours Sunrise to Sunslght.

Received By: 	REHS: <u>Jay Bhakta</u>
--	-------------------------