

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

225 N. Tehama Street, Willows, CA 95988  
Phone (530) 934-6102 FAX (530) 934-6103

Page 1 of \_\_\_\_\_

Name of Facility / DBA: <i>Orland Estates Pool</i>		Inspection Date: <i>6/24/22</i>	
Address: <i>6379 County Rd 16, Orland, CA 95963</i>		Reinspection Date (one or after): <i>Next Inspection</i> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <i>Michael Pechstien</i>	Phone Number:	Inspection Time: <i>4:35pm</i>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input type="checkbox"/> Routine Inspection <input checked="" type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH:	Free Chlorine:	Combined Chlorine:	Cyanuric Acid:
			Flow Rate:
			Temperature:
			Other:

*Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20*

<p><b>Pool Construction</b></p> <ol style="list-style-type: none"> <li>1. <input type="checkbox"/> Pool Shell</li> <li>2. <input type="checkbox"/> Bottom &amp; Sides</li> <li>3. <input type="checkbox"/> Decks &amp; Coping</li> <li>4. <input type="checkbox"/> Diving Boards</li> <li>5. <input type="checkbox"/> Depth Markers</li> <li>6. <input type="checkbox"/> Ladders/Steps/Railings</li> <li>7. <input type="checkbox"/> Underwater Lighting &amp; Electrical</li> </ol> <p><b>Recirculation Equipment</b></p> <ol style="list-style-type: none"> <li>8. <input type="checkbox"/> Filters</li> <li>9. <input type="checkbox"/> Pumps</li> <li>10. <input type="checkbox"/> Flowmeter</li> <li>11. <input type="checkbox"/> Pressure/Vacuum Gauges</li> <li>12. <input type="checkbox"/> Skimmers &amp; Gutters</li> <li>13. <input type="checkbox"/> Pipes &amp; Fittings</li> <li>14. <input type="checkbox"/> Chemical Feeders</li> <li>15. <input type="checkbox"/> Water Supply/Backflow Prevention</li> </ol>	<p><b>Water Quality</b></p> <ol style="list-style-type: none"> <li>16. <input type="checkbox"/> pH</li> <li>17. <input type="checkbox"/> Chlorine/Bromine</li> <li>18. <input type="checkbox"/> Cyanuric Acid</li> <li>19. <input type="checkbox"/> Debris in Pool</li> <li>20. <input type="checkbox"/> Water Clarity</li> <li>21. <input type="checkbox"/> Temperature</li> <li>22. <input type="checkbox"/> Flow Rate/Turnover</li> </ol> <p><b>Safety Equipment</b></p> <ol style="list-style-type: none"> <li>23. <input type="checkbox"/> Gates/Enclosure</li> <li>24. <input type="checkbox"/> Drain Covers</li> <li>25. <input type="checkbox"/> Anti-Entrapment Shutoff</li> <li>26. <input type="checkbox"/> Rescue Pole</li> <li>27. <input type="checkbox"/> Life Ring</li> <li>28. <input type="checkbox"/> Safety Signs</li> <li>29. <input type="checkbox"/> First Aid Kit</li> <li>30. <input type="checkbox"/> Chlorine Gas Safety</li> </ol>	<p><b>General Facilities</b></p> <ol style="list-style-type: none"> <li>31. <input type="checkbox"/> Exterior Lighting</li> <li>32. <input type="checkbox"/> Indoor Ventilation</li> <li>33. <input type="checkbox"/> Restrooms &amp; Toilets</li> <li>34. <input type="checkbox"/> Handwash Sinks</li> <li>35. <input type="checkbox"/> Dressing Room</li> <li>36. <input type="checkbox"/> Showers</li> <li>37. <input type="checkbox"/> Drinking Fountains</li> </ol> <p><b>Miscellaneous</b></p> <ol style="list-style-type: none"> <li>38. <input type="checkbox"/> Chemical Test Kits</li> <li>39. <input type="checkbox"/> Chemical Testing Frequency</li> <li>40. <input type="checkbox"/> Record Keeping</li> <li>41. <input type="checkbox"/> Lifeguards</li> <li>42. <input type="checkbox"/> Communicable Disease Control</li> <li>43. <input type="checkbox"/> Site Supervision &amp; Control</li> <li>44. <input type="checkbox"/> General Sanitation</li> <li>45. <input type="checkbox"/> Other:</li> </ol>
--	--	---

Comments:

*\* Pool may reopen Gate has been repaired.*

Received By: <i>[Signature]</i>	REHS: <i>John H. Wells</i>
---------------------------------	----------------------------

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988  
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <u>Orland Estates MHP Pool</u>		Inspection Date: <u>6/24/22</u>	
Address: <u>6379 County Rd 15, Orland, CA 95963</u>		Reinspection Date (on or after): <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Michael Pechstien</u>		Phone Number:	Inspection Time: <u>10:45am</u>
Permit Expiration Date:		Inspection Time: <u>10:45am</u>	
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other	
pH: <u>7.3</u>	Free Chlorine: <u>4.9 ppm</u>	Combined Chlorine: <u>0.2 ppm</u>	Cyanuric Acid: <u>39 ppm</u>
Flow Rate: <u>50 gpm</u>	Temperature: <u>Total alk - 99 ppm</u>	Other: <u>CA Hardness - 239 ppm</u>	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input checked="" type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:  
Pool is closed! Do not open without permission/approval from our department.

Critical/Closure Violation

23) Repair west entry gate so it is self-latching.

Other Violations

27) Provide rope for lifeguard that is at least as wide as pool.

28a) Provide pool capacity on sign. (capacity = 36 people).

28b) Provide "Keep closed" signs at gates to pool area.

Received By:	REHS: <u>John H. Wells</u>
--------------	----------------------------