

**SWIMMING POOL OFFICIAL INSPECTION REPORT**  
**GLENN COUNTY ENVIRONMENTAL HEALTH**

247 North Villa Avenue, Willows, CA 95988  
 Phone: (530) 934-6102 • Fax: (530) 934-6103

*check at next inspection*

Name of Facility/DBA: <b>Orland Muni Pool</b>				Inspection Date: <b>6/25/19</b>	
Address: <b>815 Fourth St, Orland, CA 95963</b>				Reinspection Date (on or after): <b>6/25/19</b> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <b>City of Orland</b>			Phone Number: <b>865-1631</b>	Inspection Time: <b>3:20 pm</b>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other			Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <b>7.3</b>	Free Chlorine: <b>0.9 ppm</b>	Combined Chlorine: <b>0.2 ppm</b>	Cyanuric Acid: <b>32 ppm</b>	Flow Rate: <b>1100 gpm</b>	Temperature: <b>Total 11k - 44 ppm</b> <b>CA Hard - 100 ppm</b>
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20					

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical  <b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	<b>Water Quality</b> 16. <input type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover  <b>Safety Equipment</b> 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input checked="" type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains  <b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:
---	--	--

Comments:

17) **Critical Violation (Correct by 12:00pm tomorrow)**  
 Maintain free available chlorine between 2.0-10.0ppm.  
 Measured 0.9 ppm.

35) **Other Violations**  
 Paint over or otherwise repair paint on end of men's dressing room bench.

Received By: Spencer Malhinney REHS: John H. Wells