

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

|  |                                  |                                      |                                 |  |  |                                     |  |
|--|----------------------------------|--------------------------------------|---------------------------------|--|--|-------------------------------------|--|
| Name of Facility/DBA:<br><b>Parkway RV Resort Pool</b>   |                                  |                                      |                                 | Inspection Date:<br><b>7/11/19</b>   |  |                                     |  |
| Address:<br><b>6330 County Road 200, Orland, CA 95963</b>  |                                  |                                      |                                 | Reinspection Date (on or after):<br><b>Next Inspection</b><br><small>(Reinspections are subject to fees)</small>   |  |                                     |  |
| Owner/Permittee:<br><b>John E. Marion Smutney</b>  |                                  | Phone Number:<br><b>865-9188</b>     |                                 | Inspection Time:<br><b>3:45pm</b>  |  | Permit Expiration Date:<br><b>-</b> |  |
| Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool<br><input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other |                                  |                                      |                                 | Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint<br><input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other |  |                                     |  |
| pH:<br><b>7.8</b>  | Free Chlorine:<br><b>1.0 ppm</b> | Combined Chlorine:<br><b>0.3 ppm</b> | Cyanuric Acid:<br><b>90 ppm</b> | Flow Rate:<br><b>20 gpm</b>  | Temperature:<br><b>Total Kit = 147</b> | Other:<br><b>2 Address = 113</b>    |  |
| Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20   |                                  |                                      |                                 |  |  |                                     |  |

|   |  |   |
|---|--|---|
| <b>Pool Construction</b><br>1. <input type="checkbox"/> Pool Shell<br>2. <input type="checkbox"/> Bottom & Sides<br>3. <input type="checkbox"/> Decks & Coping<br>4. <input type="checkbox"/> Diving Boards<br>5. <input type="checkbox"/> Depth Markers<br>6. <input type="checkbox"/> Ladders/Steps/Railings<br>7. <input type="checkbox"/> Underwater Lighting & Electrical  | <b>Water Quality</b><br>16. <input type="checkbox"/> pH<br>17. <input checked="" type="checkbox"/> Chlorine/Bromine<br>18. <input type="checkbox"/> Cyanuric Acid<br>19. <input type="checkbox"/> Debris in Pool<br>20. <input type="checkbox"/> Water Clarity<br>21. <input type="checkbox"/> Temperature<br>22. <input type="checkbox"/> Flow Rate/Turnover  | <b>General Facilities</b><br>31. <input type="checkbox"/> Exterior Lighting<br>32. <input type="checkbox"/> Indoor Ventilation<br>33. <input checked="" type="checkbox"/> Restrooms & Toilets<br>34. <input type="checkbox"/> Handwash Sinks<br>35. <input type="checkbox"/> Dressing Rooms<br>36. <input type="checkbox"/> Showers<br>37. <input type="checkbox"/> Drinking Fountains  |
| <b>Recirculation Equipment</b><br>8. <input type="checkbox"/> Filters<br>9. <input type="checkbox"/> Pumps<br>10. <input type="checkbox"/> Flowmeter<br>11. <input type="checkbox"/> Pressure/Vacuum Gauges<br>12. <input type="checkbox"/> Skimmers & Gutters<br>13. <input type="checkbox"/> Pipes & Fittings<br>14. <input type="checkbox"/> Chemical Feeders<br>15. <input type="checkbox"/> Water Supply/Backflow Prevention | <b>Safety Equipment</b><br>23. <input checked="" type="checkbox"/> Gates/Enclosure<br>24. <input type="checkbox"/> Drain Covers<br>25. <input type="checkbox"/> Anti-Entrapment Shutoff<br>26. <input type="checkbox"/> Rescue Pole<br>27. <input type="checkbox"/> Life Ring<br>28. <input type="checkbox"/> Safety Signs<br>29. <input type="checkbox"/> First Aid Kit<br>30. <input type="checkbox"/> Chlorine Gas Safety | <b>Miscellaneous</b><br>38. <input checked="" type="checkbox"/> Chemical Test Kits<br>39. <input type="checkbox"/> Chemical Testing Frequency<br>40. <input type="checkbox"/> Record Keeping<br>41. <input type="checkbox"/> Lifeguards<br>42. <input type="checkbox"/> Communicable Disease Control<br>43. <input type="checkbox"/> Site Supervision & Control<br>44. <input type="checkbox"/> General Sanitation<br>45. <input type="checkbox"/> Other: |

Comments:

**Correct the following:**

17) Maintain free chlorine at 2.0 - 10.0 ppm. Measured 1.0 ppm

23) Adjust gate so it reliably latches upon auto-closure. Gate latches most of time, but not when opened too far.

33) Provide toilet paper in restroom.

38) Obtain a DPD test kit. Operator has a OTO kit.

|                                 |                            |
|---------------------------------|----------------------------|
| Received By: <b>[Signature]</b> | REHS: <b>John H. Wells</b> |
|---------------------------------|----------------------------|