

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
 Phone: (530) 934-6102 • Fax: (530) 934-6103

| | | | | | | | |
|--|----------------------------------|--------------------------------------|----------------------------------|--|---|---------------------|-------------------------|
| Name of Facility/DBA: <u>Paigewood Apartments Spa</u> | | | | Inspection Date: <u>7/21/21</u> | | | |
| Address: <u>745 Paigewood Dr. Orland, CA 95963</u> | | | | Reinspection Date (on or after): <u>13th Sept.</u> <small>(Reinspections are subject to fees)</small> | | | |
| Owner/Permittee: <u>Orland Pacific Associates</u> | | | Phone Number: <u>855-1313</u> | | Inspection Time: <u>3:00 pm</u> | | Permit Expiration Date: |
| Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other | | | | Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other | | | |
| pH: <u>7.4</u> | Free Chlorine: <u>0.2 ppm</u> | Combined Chlorine: <u>0.2 ppm</u> | Cyanuric Acid: <u>23 ppm</u> | Flow Rate: <u>Could not determine</u> | Temperature: <u>total alk. CA hardness - 243</u> | Other: <u>51</u> | |
| Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20 | | | | | | | |

| | | |
|--|---|---|
| <p>Pool Construction</p> <p>1. <input type="checkbox"/> Pool Shell</p> <p>2. <input type="checkbox"/> Bottom & Sides</p> <p>3. <input type="checkbox"/> Decks & Coping</p> <p>4. <input type="checkbox"/> Diving Boards</p> <p>5. <input type="checkbox"/> Depth Markers</p> <p>6. <input type="checkbox"/> Ladders/Steps/Railings</p> <p>7. <input type="checkbox"/> Underwater Lighting & Electrical</p> | <p>Water Quality</p> <p>16. <input type="checkbox"/> pH</p> <p>17. <input checked="" type="checkbox"/> Chlorine/Bromine</p> <p>18. <input type="checkbox"/> Cyanuric Acid</p> <p>19. <input type="checkbox"/> Debris in Pool</p> <p>20. <input type="checkbox"/> Water Clarity</p> <p>21. <input type="checkbox"/> Temperature</p> <p>22. <input type="checkbox"/> Flow Rate/Turnover</p> | <p>General Facilities</p> <p>31. <input type="checkbox"/> Exterior Lighting</p> <p>32. <input type="checkbox"/> Indoor Ventilation</p> <p>33. <input type="checkbox"/> Restrooms & Toilets</p> <p>34. <input type="checkbox"/> Handwash Sinks</p> <p>35. <input type="checkbox"/> Dressing Rooms</p> <p>36. <input type="checkbox"/> Showers</p> <p>37. <input type="checkbox"/> Drinking Fountains</p> |
| <p>Recirculation Equipment</p> <p>8. <input type="checkbox"/> Filters</p> <p>9. <input type="checkbox"/> Pumps</p> <p>10. <input checked="" type="checkbox"/> Flowmeter</p> <p>11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges</p> <p>12. <input type="checkbox"/> Skimmers & Gutters</p> <p>13. <input type="checkbox"/> Pipes & Fittings</p> <p>14. <input type="checkbox"/> Chemical Feeders</p> <p>15. <input type="checkbox"/> Water Supply/Backflow Prevention</p> | <p>Safety Equipment</p> <p>23. <input type="checkbox"/> Gates/Enclosure</p> <p>24. <input type="checkbox"/> Drain Covers</p> <p>25. <input type="checkbox"/> Anti-Entrapment Shutoff</p> <p>26. <input type="checkbox"/> Rescue Pole</p> <p>27. <input type="checkbox"/> Life Ring</p> <p>28. <input checked="" type="checkbox"/> Safety Signs</p> <p>29. <input type="checkbox"/> First Aid Kit</p> <p>30. <input type="checkbox"/> Chlorine Gas Safety</p> | <p>Miscellaneous</p> <p>38. <input type="checkbox"/> Chemical Test Kits</p> <p>39. <input type="checkbox"/> Chemical Testing Frequency</p> <p>40. <input type="checkbox"/> Record Keeping</p> <p>41. <input type="checkbox"/> Lifeguards</p> <p>42. <input type="checkbox"/> Communicable Disease Control</p> <p>43. <input type="checkbox"/> Site Supervision & Control</p> <p>44. <input type="checkbox"/> General Sanitation</p> <p>45. <input type="checkbox"/> Other:</p> |

Comments:

* Spa is closed! Do not open without approval from our department.

Critical Violation

17) Provide 3.0 ppm of free chlorine. Measured 0.2 ppm.

Other Violations

10) Replace inoperable flow meter.

11) Replace inoperable pressure gauge.

28) Replace worn "No Diving" stickers on deck.

Received By: [Signature] REHS: John H. Wells

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
 Phone: (530) 934-6102 • Fax: (530) 934-6103

| | | | |
|--|--|--|--|
| Name of Facility/DBA: <i>Paigewood Apartments Spa</i> | | Inspection Date: <i>7/21/21</i> | |
| Address: <i>745 Paigewood Dr, Orland, CA 95963</i> | | Reinspection Date (on or after): <i>Next Inspection -</i> <small>(Reinspections are subject to fees)</small> | |
| Owner/Permittee: <i>Orland Pacific Associates</i> | Phone Number: <i>865-1313</i> | Inspection Time: <i>4:00 pm</i> | Permit Expiration Date: |
| Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other | Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other | | |
| pH: <i>7.3</i> | Free Chlorine: <i>2.5 ppm</i> | Combined Chlorine: <i>1.0 ppm</i> | Cyanuric Acid: Flow Rate: Temperature: Other: |
| <i>Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20</i> | | | |

| | | |
|---|---|--|
| Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical | Water Quality 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover | General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains |
| Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention | Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety | Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other: |

Comments:

* *Pool & Spa are cleared to reopen.*

- *Free chlorine measured 2.5 ppm. Allowed operator to add chlorine and reopen.*

All other violations from last report remain.

| | |
|---------------------------------|----------------------------|
| Received By: <i>[Signature]</i> | REHS: <i>John H. Wells</i> |
|---------------------------------|----------------------------|