SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

225 N. Tehama Street, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Name of Facility / DBA: Cedar Hills Manor			Inspection Date: 8/25/23
Address: 600 N. Humboldt Ave			Reinspection Date (one or after): next inspection (Reinspections are subject to fees)
Owner/Permittee:	Phone Number	Inspection Time: 8:00	Permit Expiration Date:

Pool Type: ☒ Swimming Pool ☐ Spa Pool ☐ Wading Pool ☐ Interactive Water Feature ☐ Other

Service: ☒ Routine Inspection ☐ Reinspection ☐ Complaint ☐ Construction/Pre-Opening ☐ Other

pH:	Free Chlorine:	Combined Chlorine:	Cyanuric Acid:	Flow Rate:	Temperature:	Other:

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction
1. ☒ Pool Shell
2. ☐ Bottom & Sides
3. ☐ Decks & Coping
4. ☐ Diving Boards
5. ☐ Depth Markers
6. ☐ Ladders/Steps/Railings
7. ☐ Underwater Lighting & Electrical

Recirculation Equipment
8. ☐ Filters
9. ☐ Pumps
10. ☐ Flowmeter
11. ☐ Pressure/Vacuum Gauges
12. ☐ Skimmers & Gutters
13. ☐ Pipes & Fittings
14. ☐ Chemical Feeders
15. ☐ Water Supply/Backflow Prevention

Water Quality
16. ☐ pH
17. ☐ Chlorine/Bromine
18. ☐ Cyanuric Acid
19. ☐ Debris in Pool
20. ☒ Water Clarity
21. ☐ Temperature
22. ☐ Flow Rate/Turnover

Safety Equipment
23. ☐ Gates/Enclosure
24. ☐ Drain Covers
25. ☐ Anti-Entrapment Shutoff
26. ☐ Rescue Pole
27. ☐ Life Ring
28. ☐ Safety Signs
29. ☐ First Aid Kit
30. ☐ Chlorine Gas Safety

General Facilities
31. ☐ Exterior Lighting
32. ☐ Indoor Ventilation
33. ☐ Restrooms & Toilets
34. ☐ Handwash Sinks
35. ☐ Dressing Room
36. ☐ Showers
37. ☐ Drinking Fountains

Miscellaneous
38. ☐ Chemical Test Kits
39. ☐ Chemical Testing Frequency
40. ☐ Record Keeping
41. ☐ Lifeguards
42. ☐ Communicable Disease Control
43. ☐ Site Supervision & Control
44. ☐ General Sanitation
45. ☐ Other:

Comments: Pool WILL REMAIN CLOSE
20) Pool is colored green / pool must be clear.
1) pool has chipped plaster / Repair or replace pool plaster.
Plan review must be submitted.
chlore feeder is broken / repair or replace feeder.

Received By: Beverly M

REHS: Jay Bhatta