

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

225 N. Tehama Street, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Page 1 of 1

Name of Facility / DBA: PAIGEWOOD APARTMENTS SPA		Inspection Date: 8/30/23	
Address: 745 PAIGEWOOD DR., ORLAND, CA		Reinspection Date (one or after): NEXT INSPECTION <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: ORLAND PACIFIC ASSOC.	Phone Number: 865-1333	Inspection Time: 9:10	Permit Expiration Date: -
Pool Type: <input type="checkbox"/> Swimming Pool <input checked="" type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input checked="" type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: 7.2	Free Chlorine: FC = 3.0 PPM	Combined Chlorine: -	Cyanuric Acid: 15 PPM
Flow Rate: UNABLE TO TEST	Temperature: -	Other: -	

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Room 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input checked="" type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input checked="" type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments: CORRECT THE FOLLOWING:

(28) REPLACE THE WORN & FADED SAFETY SIGNS.

(25) REPAIR OR REPLACE THE EMERGENCY SHUT-OFF SWITCH. IT IS OPERATIONAL BUT IF PULLED ON THE SWITCH CAN BE REMOVED.

(10) REPAIR OR REPLACE THE FLOW METERS ON POOL CIRC. EQUIPMENT.

(13) ALL PLUMBING SHALL HAVE ARROWS INDICATING DIRECTION OF FLOW.

(11) REPAIR OR REPLACE PRESSURE GAUGES ON SPA CIRC.

Received By:  REHS: 