

OFFICIAL INSPECTION REPORT

Continuation Sheet

GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

225 N. Tehama Street, Willows, CA 95988

Phone (530) 934-6102 FAX (530) 934-6103

Page 2 of 2

| | |
|---------------------------------------------|-----------------------------|
| Name of Facility / DBA: PANADAREIA REYES | Inspection Date: 9/14/23 |
| Address: | PAGE 2 |
| Owner/Permitee: | |

Comments: OTHER VIOLATIONS (CONT.)

⑥ THE HANDWASH SINK SHALL BE PROPERLY SUPPLIED WITH HAND TOWELS IN A DISPENSOR + SOAP. NOTHING SHALL BE STORED IN HAND SINK.

⑦ REPAIR/ADJUST HOT WATER SYSTEM SO THAT IT PROVIDES 120°F WATER TO SINK FIXTURES. HAND SINK NEEDS >100°F.

⑧ STORE ALL RAW P.H.F BELOW OR AWAY FROM READY TO EAT FOODS. OBSERVED RAW PORK TOUCHING RAW DOUGH IN BACK EVEREST FRIDGE.

⑨ REPLACE NON-COMMERCIAL M-WAVE WITH COMMERCIAL GRADE UNIT.

⑩ REPAIR AND START USING THE FACILITY MOP SINK. ALL MOP SINK WASTE WATER SHALL BE DUMPED HERE.

⑪ REPAIR THE LIGHTING IN THE KITCHEN SO THAT IT IS MUCH BRIGHTER.

⑫ PROVIDE A PROPER AIR-GAP ON THE 3-COMPARTMENT SINK FOR BACKFLOW PREVENTION.

| | |
|---------------------------------|------------------------------------|
| Received By: <i>[Signature]</i> | REHS: <i>Andrew A. [Signature]</i> |
|---------------------------------|------------------------------------|