

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>Willows Century Pool, Inc.</u>		Inspection Date: <u>9/19/18</u>	
Address: <u>551 WASHINGTON ST., Willows, CA 95988</u>		Reinspection Date (on or after): <u>NEXT INSPECTION</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Willows Century Pool Inc.</u>	Phone Number: <u>867-6482</u>	Inspection Time: <u>9:30</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other	
pH: <u>7.8</u>	Free Chlorine: <u>15.2 PPM</u>	Combined Chlorine: <u>NOT TESTED</u>	Cyanuric Acid: <u>~ 67 PPM</u>
Flow Rate: <u>59 GPM</u>		Temperature:	Other:

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction	Water Quality	General Facilities
1. <input type="checkbox"/> Pool Shell	16. <input type="checkbox"/> pH	31. <input type="checkbox"/> Exterior Lighting
2. <input type="checkbox"/> Bottom & Sides	17. <input type="checkbox"/> Chlorine/Bromine	32. <input type="checkbox"/> Indoor Ventilation
3. <input type="checkbox"/> Decks & Coping	18. <input type="checkbox"/> Cyanuric Acid	33. <input type="checkbox"/> Restrooms & Toilets
4. <input type="checkbox"/> Diving Boards	19. <input type="checkbox"/> Debris in Pool	34. <input type="checkbox"/> Handwash Sinks
5. <input type="checkbox"/> Depth Markers	20. <input type="checkbox"/> Water Clarity	35. <input type="checkbox"/> Dressing Rooms
6. <input type="checkbox"/> Ladders/Steps/Railings	21. <input type="checkbox"/> Temperature	36. <input type="checkbox"/> Showers
7. <input type="checkbox"/> Underwater Lighting & Electrical	22. <input checked="" type="checkbox"/> Flow Rate/Turnover	37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment	Safety Equipment	Miscellaneous
8. <input checked="" type="checkbox"/> Filters <u>LOS AP</u>	23. <input type="checkbox"/> Gates/Enclosure	38. <input type="checkbox"/> Chemical Test Kits
9. <input type="checkbox"/> Pumps	24. <input type="checkbox"/> Drain Covers	39. <input type="checkbox"/> Chemical Testing Frequency
10. <input checked="" type="checkbox"/> Flowmeter <u>LOS AP</u>	25. <input type="checkbox"/> Anti-Entrapment Shutoff	40. <input type="checkbox"/> Record Keeping
11. <input type="checkbox"/> Pressure/Vacuum Gauges	26. <input type="checkbox"/> Rescue Pole	41. <input type="checkbox"/> Lifeguards
12. <input type="checkbox"/> Skimmers & Gutters	27. <input checked="" type="checkbox"/> Life Ring	42. <input type="checkbox"/> Communicable Disease Control
13. <input checked="" type="checkbox"/> Pipes & Fittings	28. <input type="checkbox"/> Safety Signs	43. <input type="checkbox"/> Site Supervision & Control
14. <input type="checkbox"/> Chemical Feeders	29. <input type="checkbox"/> First Aid Kit	44. <input type="checkbox"/> General Sanitation
15. <input type="checkbox"/> Water Supply/Backflow Prevention	30. <input type="checkbox"/> Chlorine Gas Safety	45. <input type="checkbox"/> Other:

Comments: VIOLATIONS:

⑧ REPAIR LEAK ON THE FILTER BELLY BAND. ~ OPERATOR CORRECTED LEAK BY TIGHTENING THE BAND.

⑩ REPAIR THE LEAK ON THE FLOW METER ON THE PLUMBING. ~ OPERATOR CORRECTED LEAK W/ SILICON TAPE.

⑬ REPAIR & LOOK INTO THE SUMP INSIDE THE POOL EQUIPMENT ROOM. IT WAS OBSERVED TO BE FILLING W/ WATER & THE PUMP DID NOT APPEAR OPERATIONAL.

⑳ MAINTAIN PROPER POOL TURNOVER RATE. THE POOL DID NOT MEET REQUIRED TURN OVER RATE. WE RECOMMEND PLANNING/MAKING CAPITAL IMPROVEMENTS TO POOL INFRASTRUCTURE TO MEET TURNOVER TIMES.

VACUUM = 13 inHg
PSI = 25 PSI

Pool Vol = 65,910 ∴ $\frac{65,910 \text{ G}}{39 \text{ GPM} \times 60 \frac{\text{min}}{\text{hr}}} = 18.6 \text{ HR}$

CURRENT PUMP = INTELLIFLO VST SURF (PUMP) TURNOVER

Received By: X [Signature] REHS: Andrew Petyo

⑳ MOVE LIFE RING AND ROPE TO HOOK ON THE FRONT OF THE POOL HOUSE. Revised September 9, 2015