

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>HOLIDAY INN EXPRESS SPA</u>		Inspection Date: <u>6/8/16</u>	
Address: <u>249 N. HUMBOLDT AVE, WILLOWS</u>		Reinspection Date (on or after): <u>NEXT INSPECTION</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>KUMAR HOTELS INC</u>	Phone Number:	Inspection Time: <u>3:30</u>	Permit Expiration Date:
Pool Type: <input type="checkbox"/> Swimming Pool <input checked="" type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <u>7.0</u>	Free Chlorine: <u>N3.2 PPM</u>	Combined Chlorine: <u>NOI TESTED</u>	Cyanuric Acid: <u>N17 PPM</u>
	Flow Rate: <u>UNABLE TO TEST</u>	Temperature: <u>104°F</u>	Other: <u>-</u>

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Water Quality 16. <input checked="" type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Other Chemicals 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input checked="" type="checkbox"/> Other:
---	---	---

Comments:

VIOLATIONS

(10) REPAIR OR REPLACE THE FLOW METER ON THE SPA CIRCULATION EQUIPMENT.

(16) MAINTAIN SPA pH AT A RANGE OF 7.2-7.8 AT ALL TIMES. SPA pH MEASURED 7.0 WHICH WILL BE IRRITATING TO SWIMMER EYES AN CORROSIVE ON POOL EQUIPMENT.

(17) CHEMICAL RECORDS INDICATE SPA CHLORINE LEVELS HAVE BEEN UNDER MINIMUM LEVELS FOR THE PAST WEEK. MAINTAIN SPA CHLORINE LEVELS AT 3.0 PPM AT ALL TIMES.

(28) INDICATE SPA SWIMMER CAPACITY ON SIGN POSTED AT SPA.

(40) TEST & RECORD CYANURIC ACID ON A ONCE PER MONTH BASIS (MAY WAS MISSING)

(45) VARIABLE SPEED PUMP AT THE SPA MUST HAVE G.C.E.H. PROGRAM APPROVAL BEFORE BEING USED. FILL OUT PAPERWORK AT G.C.E.H.

Received By: [Signature] REHS: ANDREW [Signature] REPEAT VIOLATION!

(45) NEW SPA FILTER MUST BE PLAN CHECKED BY G.C.E.H AND APPROVED BEFORE INSTALLATION. PLAN CHECK WITH OUR DEPARTMENT.