

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
 Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: Blue Gum Motel		Inspection Date: 8/26/14	
Address: 2637 Highway 99W, Willows, CA		Reinspection Date (on or after): NEXT INSPECTION <small>(Reinspections are subject to fees)</small>	
Owner/Permittee:	Phone Number:	Inspection Time: 4:00	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: 7.2	Free Chlorine: 23.5 PPM	Combined Chlorine: -	Cyanuric Acid: ~40 PPM
Flow Rate: < 40 GPM	Temperature: -	Other: -	

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

<p>Pool Construction</p> <ol style="list-style-type: none"> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input checked="" type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical <p>Recirculation Equipment</p> <ol style="list-style-type: none"> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention 	<p>Water Quality</p> <ol style="list-style-type: none"> 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Other Chemicals 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input checked="" type="checkbox"/> Flow Rate/Turnover <p>Safety Equipment</p> <ol style="list-style-type: none"> 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety 	<p>General Facilities</p> <ol style="list-style-type: none"> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains <p>Miscellaneous</p> <ol style="list-style-type: none"> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input checked="" type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:
--	---	--

Comments:

CORRECT THE FOLLOWING:

3) REPAIR LARGE CRACKS ACROSS DECK OF POOL.

11) REPAIR/REPLACE RETURN LINE PRESSURE GAUGE OR REPAIR LEAKY PLUMBING, SO PRESSURE CAN BE MEASURED

28) PROVIDE EASILY READABLE SIGNS FOR THE FOLLOWING!

- 1) DIABETHA SIGN (FRONT GATE)
- 2) KEEP GATE CLOSED (FRONT GATE)
- 3) POOL HOURS
- 4) SWIMMER CAPACITY (1 PERSON PER 15FT²)

40) KEEP DAILY RECORDS FOR pH & CHLORINE & RECORD, ONCE PER MONTH, CYANURIC ACID READINGS.

43) MAINTAIN PEST CONTROL IN POOL CIRCULATION ROOM SO THAT IT IS SAFE TO ENTER & INSPECT.

Received By: X Prantina Patin REHS: Andrew Petyo