

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: BLUE GUM MOTEL				Inspection Date: 8/30/17			
Address: 2637 Hwy 99W, Willows, CA				Reinspection Date (on or after): * POOL IS CLOSED <small>(Reinspections are subject to fees)</small>			
Owner/Permittee: PRATIMA PATEL			Phone Number:		Inspection Time: 11:00		Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other			Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other				
pH: 6.6	Free Chlorine: 2.5 PPM	Combined Chlorine: 2.7 PPM	Cyanuric Acid: >100 PPM	Flow Rate: 110 GPM	Temperature:	Other:	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20							

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input checked="" type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Water Quality 16. <input checked="" type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input checked="" type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input checked="" type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:
--	---	--

Comments:

**** POOL IS CLOSED ON THE ABOVE DATE & TIME FOR THE FOLLOWING CRITICAL VIOLATIONS.**

**** CRITICAL VIOLATIONS ****

(16) MAINTAIN POOL pH BETWEEN 7.2-7.8 AT ALL TIMES. POOL pH MEASURED AT 6.6 WHICH IS EXTREMELY LOW AND VERY BAD FOR POOL EQUIPMENT.

(18) MAINTAIN POOL STABILIZER (CYANURIC ACID) AT LESS THAN 100 PPM. MEASURE CYA AT 7100 PPM. DRAIN POOL WATER 1/2 WAY & REPLACE WITH FRESH.

OTHER VIOLATIONS

(11) PROVIDE A WORKING VACUUM GAUGE ON POOL PUMP SUCTION SIDE.

(20) POOL WATER SHALL BE CLEAN & CLEAR AT ALL TIMES.

(28) POOLSIDE SAFETY SIGNS SHALL INDICATE HOURS OF OPERATION.

(40) RECORD DAILY pH & FREE CHLORINE & ONCE PER MONTH CYANURIC ACID LOG BOOK LACKED MANY DAYS OF RECORDS.

Received By:  REHS: **ANDREW PETRO**