

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of _____

Name of Facility/DBA: Willows Century Pool		Inspection Date: 9/14/17	
Address: 551 WASHINGTON ST, WILLOWS, CA 95988		Reinspection Date (on or after): NEXT INSPECTION <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: Willows Century Pool Inc.	Phone Number: 867-6482	Inspection Time: 9:30	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: 7.6	Free Chlorine: 2.5.6 PPM	Combined Chlorine: NOT TESTED	Cyanuric Acid: ~ 29 PPM
Flow Rate: 125 GPM	Temperature: NOT TESTED	Other: -	

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input checked="" type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input checked="" type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:

NO CRITICAL VIOLATIONS

CORRECT THE FOLLOWING

⑩ REPLACE THE FLOWMETER ON THE POOL PLUMBING SO THAT THE CORRECT SCALE IS INDICATED AND IT IS EASILY READABLE.

⑮ PROVIDE A BACKFLOW PREVENTION DEVICE ON THE BOTTOM SPIGOT AT THE DRINKING FOUNTAIN.

⑳ MAINTAIN THE PROPER POOL TURNOVER RATE, POOL DID NOT MEET REQUIRED TURNOVER RATE. WE RECOMMEND PLANNING/MAKING IMPROVEMENTS TO POOL INFRASTRUCTURE TO MEET TURNOVER TIMES.

VACUUM = 14 in Hg
PSI = 12 PSI

$$\text{BCL VOL} = 65,910 \therefore \frac{65,910 \text{ G}}{(125 \text{ GPM})(60 \text{ MIN/HR})} = 8.8 \text{ HRS}$$

CURRENT PUMP: INTELLIFLO VST SVRS (LABEL PUMP 2)

Received By: [Signature]	REHS: Andrew [Signature]
---------------------------------	---------------------------------