

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <u>Blue Gum Motel Pool</u>		Inspection Date: <u>9/20/16</u>	
Address: <u>2637 C/R 99W, Willows, CA</u>		Reinspection Date (on or after): <u>**POOL IS CLOSED**</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>OFFSET INVESTMENTS, LLC</u>	Phone Number:	Inspection Time: <u>3:30</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <u>7.8</u>	Free Chlorine: <u>1.4 PPM</u>	Combined Chlorine: <u>NOT TESTED</u>	Cyanuric Acid: <u>1.46 PPM</u>
Flow Rate: <u>UNABLE TO TEST</u>	Temperature: <u>-</u>	Other:	

Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input checked="" type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input checked="" type="checkbox"/> Water Supply/Backflow Prevention	Water Quality 16. <input type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover Safety Equipment 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input checked="" type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:
---	--	--

Comments:
**POOL IS CLOSED ON THE ABOVE DATE FOR THE FOLLOWING CRITICAL VIOLATIONS:
CRITICAL VIOLATIONS
9) POOL RE-CIRCULATION PUMP WAS NOT OPERATING NORMALLY OR UNDER THE APPROVED OPERATIONAL TIME & SPEED SETTINGS. POOL CLARITY IS POOR DUE TO CIRCULATION.
17) MAINTAIN POOL FREE AVAILABLE CHLORINE AT/ABOVE 2.0 PPM AND LESS THAN 1.0 PPM AT ALL TIMES. POOL MEASURED 1.4 PPM.
23) ALL ENTRY GATES MUST BE SELF-CLOSING & SELF LATCHING IN BOTH DIRECTIONS. 1 ENTRY GATE WAS NOT CLOSING/LATCHING.
OTHER VIOLATIONS
15) PROVIDE A BACKFLOW PREVENTION DEVICE ON THE HOSE THAT FILLS THE POOL
27) ATTACH A NEW ROPE TO THE LIFE RING. THE EXISTING ONE IS REALLY OLD & FRAIDED
40) TEST AND RECORD DAILY THE pH & FREE AVAILABLE CHLORINE LOG BOOK WAS MISSING SOME DAYS

Received By: [Signature] REHS: Andrew [Signature]