

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
 Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>Willows Springs Senior Apt.</u>		Inspection Date: <u>9/29/15</u>	
Address: <u>1340 W. SYCAMORE ST., WILLOWS, CA</u>		Reinspection Date (on or after): <u>*POOL IS CLOSED</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee:	Phone Number:	Inspection Time: <u>3:00</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <u>7.3</u>	Free Chlorine: <u>2.8 PPM</u>	Combined Chlorine: <u>0</u>	Cyanuric Acid: <u>>100 PPM</u>
Flow Rate: <u>70 GPM</u>	Temperature: <u>N/A</u>	Other: <u>-</u>	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

Pool Construction	Water Quality	General Facilities
1. <input type="checkbox"/> Pool Shell	16. <input type="checkbox"/> pH	31. <input type="checkbox"/> Exterior Lighting
2. <input type="checkbox"/> Bottom & Sides	17. <input type="checkbox"/> Chlorine	32. <input type="checkbox"/> Indoor Ventilation
3. <input type="checkbox"/> Decks & Coping	18. <input checked="" type="checkbox"/> Cyanuric Acid	33. <input type="checkbox"/> Restrooms & Toilets
4. <input type="checkbox"/> Diving Boards	19. <input type="checkbox"/> Other Chemicals	34. <input type="checkbox"/> Handwash Sinks
5. <input type="checkbox"/> Depth Markers	20. <input type="checkbox"/> Water Clarity	35. <input type="checkbox"/> Dressing Rooms
6. <input type="checkbox"/> Ladders/Steps/Railings	21. <input type="checkbox"/> Temperature	36. <input type="checkbox"/> Showers
7. <input type="checkbox"/> Underwater Lighting & Electrical	22. <input type="checkbox"/> Flow Rate/Turnover	37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment	Safety Equipment	Miscellaneous
8. <input type="checkbox"/> Filters	23. <input type="checkbox"/> Gates/Enclosure	38. <input type="checkbox"/> Chemical Test Kits
9. <input type="checkbox"/> Pumps	24. <input type="checkbox"/> Drain Covers	39. <input type="checkbox"/> Chemical Testing Frequency
10. <input type="checkbox"/> Flowmeter	25. <input type="checkbox"/> Anti-Entrapment Shutoff	40. <input checked="" type="checkbox"/> Record Keeping
11. <input type="checkbox"/> Pressure/Vacuum Gauges	26. <input type="checkbox"/> Rescue Pole	41. <input type="checkbox"/> Lifeguards
12. <input type="checkbox"/> Skimmers & Gutters	27. <input type="checkbox"/> Life Ring	42. <input type="checkbox"/> Communicable Disease Control
13. <input type="checkbox"/> Pipes & Fittings	28. <input type="checkbox"/> Safety Signs	43. <input type="checkbox"/> Site Supervision & Control
14. <input type="checkbox"/> Chemical Feeders	29. <input type="checkbox"/> First Aid Kit	44. <input type="checkbox"/> General Sanitation
15. <input type="checkbox"/> Water Supply/Backflow Prevention	30. <input type="checkbox"/> Chlorine Gas Safety	45. <input type="checkbox"/> Other:

Comments:

~~***CRITICAL VIOLATION***~~
 (CYANURIC ACID)

(18) MAINTAIN POOL STABILIZER <100 PPM AT ALL TIMES, TO REDUCE STABILIZER POOL MUST BE AT LEAST PARTIALLY DRAINED & FRESH WATER ADDED.

OTHER VIOLATIONS

(19) RECORD & TEST CHLORINE & pH ON A DAILY BASIS. RECORD CYANURIC ACID READING MONTHLY. KEEP RECORDS AVAILABLE FOR SURPRISE INSPECTION.

NOTE: POOL IS CLOSED ON ABOVE DATE & TIME FOR THE ABOVE CRITICAL VIOLATION. ONCE CORRECTED CALL FOR AN RE-INSPECTION.

Received By: Sumette Cingland REHS: Andrew Perry