

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 1

Name of Facility/DBA: <u>Willow Springs Apartments</u>		Inspection Date: <u>9/5/17</u>	
Address: <u>1340 W. Sycamore St., Willows.</u>		Reinspection Date (on or after): <b>**POOL IS CLOSED**</b> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Willows Pacific Assoc CALP</u>	Phone Number: <u>934-3411</u>	Inspection Time: <u>3:30</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other	
pH: <u>7.5</u>	Free Chlorine: <u>3.8</u>	Combined Chlorine: <u>NOT TESTED</u>	Cyanuric Acid: <u>224 PPM</u>
Flow Rate: <u>UNABLE TO TEST</u>		Temperature: <u>—</u>	Other: <u>—</u>
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input checked="" type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments:

**\*\*POOL IS CLOSED ON THE ABOVE DATE & TIME FOR THE FOLLOWING CRITICAL VIOLATIONS.**

**\*\*CRITICAL VIOLATIONS\*\***

**(23) ALL ENTRY GATES MUST BE SELF-CLOSING & SELF-CATCHING AT ALL TIMES. RE-LUBRICATE AND/OR TIGHTEN SPRING ON THE GATES**

**OTHER VIOLATIONS**

**(10) REPAIR OR REPLACE THE FLOW METER ON THE POOL EQUIPMENT.**

**(43) CLEARLY MARK HOURS OF OPERATION ON THE POOL SIGNS DIRECTLY ADJACENT TO THE POOL**

**(10) RECORD DAILY pH & FREE CHLORINE MEASUREMENTS AND ANY MAINTENANCE OR CORRECTIVE ACTIONS TAKEN. TEST & RECORD, ONCE PER MONTH, CYANURIC ACID (STABILIZER) READINGS.**

Received By: Judy Manning

REHS: Andrew Tetko