

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988

Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <u>Tierradel Sal Apartments Pool</u>		Inspection Date: <u>7/11/18</u>	
Address: <u>73 E. Walker St, Orland, CA 95963</u>		Reinspection Date (on or after): <u>3w Appointment</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: <u>Robert Howard</u>		Phone Number:	Inspection Time: <u>10:10am</u>
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other		Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other	
pH: <u>7.6</u>	Free Chlorine: <u>0.13 ppm</u>	Combined Chlorine: <u>0.25 ppm</u>	Cyanuric Acid: <u>89 ppm</u>
Flow Rate: <u>Unknown</u>	Temperature: <u>Total alk + 117 ppm</u>	Other: <u>CA Hardness - 291 ppm</u>	
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq., California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input checked="" type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments: * Pool is closed! Do not reopen without approval from our office.

Critical Violations (Closure Violations)

17) Maintain free chlorine between 2.0 - 10.0 ppm. Free chlorine measured 0.1 ppm.

23) Repair entrance gate so that it is both self-closing and self-latching. Self-closing mechanism on gate is broken. Also, trees adjacent to gate need to be trimmed so gate does not get caught on branches/leaves.

Other Violations

10) Replace inoperable flow meter.

17) Provide rope (equal to width of pool), attach to lifering.

Received By: [Signature] REHS: John H. Wells

Pool

~~FOOD~~ FACILITY INSPECTION REPORT

Continuation Sheet

GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

247 North Villa Avenue, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103


Page 2 of 2

Name of Facility/ DBA: Tierra Del Sol Apartments Pool	Inspection Date: 7/11/18
Address: 73 E. Walker St, Oland, CA 95963	
Owner/Permitee: Robert Howard	
Applicable Law CALIFORNIA RETAIL FOOD CODE ("CalCode), Beginning with section 113700, California Health and Safety Code	

Comments:

Other Violations (Continued)

- 28) Provide all required safety signs, and replace faded safety signs. Observed:
- a) Diarrhea warning sign is faded.
 - b) Emergency Contact #/911 is faded.
 - c) Apartment complex address sign is missing.
 - d) Pool capacity sign is missing.
 - e) 3 of 6 depth markers on deck are missing the words "No Diving" and/or the diagram with a diver with a circle and line through it.

Received By: 	REHS: John H. Wells
--	---------------------