

# SWIMMING POOL OFFICIAL INSPECTION REPORT

## GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988  
Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: <u>DOLPHIN CLUB</u>		Inspection Date: <u>9/12/18</u>	
Address: <u>233 W. 1ST AVE, Willows, CA</u>		Reinspection Date (on or after): <u>NEXT INSPECTION</u> <small>(Reinspections are subject to fees)</small>	
Owner/Permittee:	Phone Number:	Inspection Time: <u>9:30</u>	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <u>7.8</u>	Free Chlorine: <u>~4.0 PPM</u>	Combined Chlorine: <u>-</u>	Cyanuric Acid: <u>73 PPM</u>
Flow Rate: <u>EAST WEST UNABLE TO TEST</u>		Temperature: <u>-</u>	Other: <u>-</u>
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

<b>Pool Construction</b> 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input checked="" type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input checked="" type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	<b>Water Quality</b> 16. <input type="checkbox"/> pH 17. <input type="checkbox"/> Chlorine/Bromine 18. <input type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Debris in Pool 20. <input type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	<b>General Facilities</b> 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
<b>Recirculation Equipment</b> 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input checked="" type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input checked="" type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input checked="" type="checkbox"/> Water Supply/Backflow Prevention	<b>Safety Equipment</b> 23. <input checked="" type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	<b>Miscellaneous</b> 38. <input type="checkbox"/> Chemical Test Kits 39. <input type="checkbox"/> Chemical Testing Frequency 40. <input checked="" type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input checked="" type="checkbox"/> Site Supervision & Control 44. <input type="checkbox"/> General Sanitation 45. <input type="checkbox"/> Other:

Comments: VIOLATIONS

3 REPAIR/SEAL GAPS & CRACKS ALONG THE DECK OF THE POOL

5 RE-PAINT THE DECK DEPTH MARKERS AS THEY ARE FADED.

10 REPLACE BROKEN FLOW METER ON THE EAST SIDE PLUMBING

13 REPAIR LEAK NEAR THE FLOW METER ON PLUMBING.

15 LOWER THE WATER LEVEL IN THE POOL SO THAT THE SKIMMER SYSTEM WORKS PROPERLY.

23 LUBRICATE THE HINGES ON THE ENTRY GATE SO THAT DOOR CLOSES BETTER.

28 REPLACE THE "NO LIFEGUARD ON DUTY" SIGNS, THEY ARE REALLY FADED.

28 RE-PAINT OR PARKEN SIGN WITH THE POOL HOURS.

40 RECORD pH & FREE CHLORINE ON A DAILY BASIS. SOME DAYS WERE MISSING.

43 KEEP EQUIPMENT ROOM LOCKED & SECURED TO PREVENT UNAUTHORIZED ENTRY.

Received By: <u>[Signature]</u>	REHS: <u>Andrew Perry</u>
---------------------------------	---------------------------