

SWIMMING POOL OFFICIAL INSPECTION REPORT
GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
 Phone: (530) 934-6102 • Fax: (530) 934-6103

Name of Facility/DBA: Las Palmas Apartments Pool		Inspection Date: 6/26/15	
Address: 68 E. Walker St, Orland, CA 95963		Reinspection Date (on or after): By Appointment <small>(Reinspections are subject to fees)</small>	
Owner/Permittee: Benigno Casillas	Phone Number: 520-0054	Inspection Time: 9:45am	Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other	Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: 7.3	Free Chlorine: 0.3 ppm	Combined Chlorine: 0.3 ppm	Cyanuric Acid: 33 ppm
Flow Rate: Could not determine		Temperature: -	Other: Tot Alk - 111 Calc Hard - 252
Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20			

Pool Construction	Water Quality	General Facilities
1. <input type="checkbox"/> Pool Shell	16. <input type="checkbox"/> pH	31. <input type="checkbox"/> Exterior Lighting
2. <input type="checkbox"/> Bottom & Sides	17. <input checked="" type="checkbox"/> Chlorine	32. <input type="checkbox"/> Indoor Ventilation
3. <input type="checkbox"/> Decks & Coping	18. <input type="checkbox"/> Cyanuric Acid	33. <input type="checkbox"/> Restrooms & Toilets
4. <input type="checkbox"/> Diving Boards	19. <input type="checkbox"/> Other Chemicals	34. <input type="checkbox"/> Handwash Sinks
5. <input checked="" type="checkbox"/> Depth Markers	20. <input checked="" type="checkbox"/> Water Clarity	35. <input type="checkbox"/> Dressing Rooms
6. <input type="checkbox"/> Ladders/Steps/Railings	21. <input type="checkbox"/> Temperature	36. <input type="checkbox"/> Showers
7. <input type="checkbox"/> Underwater Lighting & Electrical	22. <input type="checkbox"/> Flow Rate/Turnover	37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment	Safety Equipment	Miscellaneous
8. <input type="checkbox"/> Filters	23. <input type="checkbox"/> Gates/Enclosure	38. <input type="checkbox"/> Chemical Test Kits
9. <input type="checkbox"/> Pumps	24. <input type="checkbox"/> Drain Covers	39. <input checked="" type="checkbox"/> Chemical Testing Frequency
10. <input type="checkbox"/> Flowmeter	25. <input type="checkbox"/> Anti-Entrapment Shutoff	40. <input type="checkbox"/> Record Keeping
11. <input type="checkbox"/> Pressure/Vacuum Gauges	26. <input type="checkbox"/> Rescue Pole	41. <input type="checkbox"/> Lifeguards
12. <input type="checkbox"/> Skimmers & Gutters	27. <input type="checkbox"/> Life Ring	42. <input type="checkbox"/> Communicable Disease Control
13. <input type="checkbox"/> Pipes & Fittings	28. <input type="checkbox"/> Safety Signs	43. <input type="checkbox"/> Site Supervision & Control
14. <input type="checkbox"/> Chemical Feeders	29. <input type="checkbox"/> First Aid Kit	44. <input type="checkbox"/> General Sanitation
15. <input type="checkbox"/> Water Supply/Backflow Prevention	30. <input type="checkbox"/> Chlorine Gas Safety	45. <input type="checkbox"/> Other:

Comments:

* Pool is Closed. Do not reopen without approval from our department.

* Critical Violation (Closure Violation)

17) Provide 2.0 ppm of free chlorine. Measured 0.3 ppm in shallow end of pool.

Other Violations

5) Provide "No Diving" graphic sign adjacent to all depth markers on deck. Deck only has written "No Diving"

20a) Clarify water. Water is slightly cloudy, though main drain is visible.

20b) Clean debris from pool.

39) Test for free chlorine & pH daily. Operator records show testing on 6 of last 25 days.

Received By: John H. Wells <i>- Received via US Mail</i>	REHS: John H. Wells
--	----------------------------