

SWIMMING POOL OFFICIAL INSPECTION REPORT

GLENN COUNTY ENVIRONMENTAL HEALTH

247 North Villa Avenue, Willows, CA 95988
Phone: (530) 934-6102 • Fax: (530) 934-6103

Page 1 of 2

Name of Facility/DBA: <u>Las Palmas Apartments Pool</u>				Inspection Date: <u>9/3/15</u>		
Address: <u>68 E. Walker St, Orland, CA 95963</u>				Reinspection Date (on or after): <u>By Appointment</u> <small>(Reinspections are subject to fees)</small>		
Owner/Permittee: <u>Benigno Casillas</u>		Phone Number: <u>520-0054</u>		Inspection Time: <u>4:10pm</u>		Permit Expiration Date:
Pool Type: <input checked="" type="checkbox"/> Swimming Pool <input type="checkbox"/> Spa Pool <input type="checkbox"/> Wading Pool <input type="checkbox"/> Interactive Water Feature <input type="checkbox"/> Other				Service: <input checked="" type="checkbox"/> Routine Inspection <input type="checkbox"/> Reinspection <input type="checkbox"/> Complaint <input type="checkbox"/> Construction/Pre-Opening <input type="checkbox"/> Other		
pH: <u>7.3</u>	Free Chlorine: <u>0.2 ppm</u>	Combined Chlorine: <u>0 ppm</u>	Cyanuric Acid: <u>125+ ppm</u>	Flow Rate: <u>Not Measurable</u>	Temperature: <u>-</u>	Other: <u>-</u>
<small>Applicable Laws & Regulations: California Health & Safety Code § 116025 et. seq.; California Code of Regulations Title 24, Chapter 31 & Title 22, Chapter 20</small>						

Pool Construction 1. <input type="checkbox"/> Pool Shell 2. <input type="checkbox"/> Bottom & Sides 3. <input type="checkbox"/> Decks & Coping 4. <input type="checkbox"/> Diving Boards 5. <input type="checkbox"/> Depth Markers 6. <input type="checkbox"/> Ladders/Steps/Railings 7. <input type="checkbox"/> Underwater Lighting & Electrical	Water Quality 16. <input type="checkbox"/> pH 17. <input checked="" type="checkbox"/> Chlorine 18. <input checked="" type="checkbox"/> Cyanuric Acid 19. <input type="checkbox"/> Other Chemicals 20. <input checked="" type="checkbox"/> Water Clarity 21. <input type="checkbox"/> Temperature 22. <input type="checkbox"/> Flow Rate/Turnover	General Facilities 31. <input type="checkbox"/> Exterior Lighting 32. <input type="checkbox"/> Indoor Ventilation 33. <input type="checkbox"/> Restrooms & Toilets 34. <input type="checkbox"/> Handwash Sinks 35. <input type="checkbox"/> Dressing Rooms 36. <input type="checkbox"/> Showers 37. <input type="checkbox"/> Drinking Fountains
Recirculation Equipment 8. <input type="checkbox"/> Filters 9. <input type="checkbox"/> Pumps 10. <input type="checkbox"/> Flowmeter 11. <input type="checkbox"/> Pressure/Vacuum Gauges 12. <input type="checkbox"/> Skimmers & Gutters 13. <input type="checkbox"/> Pipes & Fittings 14. <input type="checkbox"/> Chemical Feeders 15. <input type="checkbox"/> Water Supply/Backflow Prevention	Safety Equipment 23. <input type="checkbox"/> Gates/Enclosure 24. <input type="checkbox"/> Drain Covers 25. <input type="checkbox"/> Anti-Entrapment Shutoff 26. <input type="checkbox"/> Rescue Pole 27. <input type="checkbox"/> Life Ring 28. <input checked="" type="checkbox"/> Safety Signs 29. <input type="checkbox"/> First Aid Kit 30. <input type="checkbox"/> Chlorine Gas Safety	Miscellaneous 38. <input type="checkbox"/> Chemical Test Kits 39. <input checked="" type="checkbox"/> Chemical Testing Frequency 40. <input type="checkbox"/> Record Keeping 41. <input type="checkbox"/> Lifeguards 42. <input type="checkbox"/> Communicable Disease Control 43. <input type="checkbox"/> Site Supervision & Control 44. <input checked="" type="checkbox"/> General Sanitation 45. <input checked="" type="checkbox"/> Other: <u>water level</u>

Comments:

* Pool is closed! Do not reopen with approval from our department.

* Critical Violations (Closure Violations)

17) Provide 2-0-10-0 ppm of free available chlorine. Measured 0-2 ppm free chlorine.

18) Maintain cyanuric acid below 100 ppm. Measured 125 ppm of cyanuric acid (30 ppm is ideal).

Other Violations

20) Remove cloudiness from water. Water has white cloudiness. Main drain is still easily visible.

39) Test for free chlorine & pH daily. Test log shows no tests for dates between 7/31/15 - 8/19/15 and 8/21/15 to present.

44) Clean leaves & dirt from bottom of pool.

Received By: Sent via US Mail REHS: John H Wells

OFFICIAL INSPECTION REPORT
Continuation Sheet
GLENN COUNTY ENVIRONMENTAL HEALTH DEPARTMENT
257 North Villa Avenue, Willows, CA 95988
Phone (530) 934-6102 FAX (530) 934-6103

Name of Facility/ DBA: <u>Las Palmas Apartments Pool</u>	Inspection Date: <u>9/3/15</u>
Address: <u>68 E. Walker St, Orland, CA 95963</u>	
Owner/Permitee: <u>Benigno Casillas</u>	

Comments:
Other violations (continued)

28) Provide the words "No Diving" along with the international symbol for no diving (a swimmer diving with a circle S, line through it) adjacent to all depth markers on deck. Deck has only the words "no diving" on deck in 3 locations and no graphical symbol.

45) Increase water level to midpoint of skimmers. Water level is below skimmers. Also, pump is making loud buzzing sound due to operation without water running through system.

Received By: <u>Sent via US Mail</u>	REHS: <u>John H. Wells</u>
--------------------------------------	----------------------------